



**HELLENIC GAS  
TRANSMISSION  
SYSTEM OPERATOR**

357-359, MESSOGION AVE.,  
15231 ATHENS, GREECE  
Tel.: 210 6501258  
Fax : 210 6501551

**TECHNICAL JOB  
SPECIFICATION**

**799/6**

**REVISION 0**

**DATE 05/04/2011**

# **HIGH PRESSURE (HP) TRANSMISSION SYSTEMS**

## **CATHODIC PROTECTION COMMISSIONING AND START-UP**



**HELLENIC GAS TRANSMISSION SYSTEM OPERATOR**

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 2/12

**QUALITY ASSURANCE PAGE**

**CHANGES LOG**

**REVISIONS LOG**

0	05-04-2011	FIRST ISSUE	PQ DPT.	V.G.
Rev. No	Rev. Date	REASON FOR CHANGE	Made By	Approved By

**CONTENTS**

**REFERENCE DOCUMENTS**

- 1.0 SCOPE**
- 2.0 GENERAL**
- 3.0 ACTIONS BEFORE SETTING IN OPERATION**
- 4.0 START-UP OF THE SYSTEM - PHASE 1**
- 5.0 CONTROL MEASUREMENTS - PHASE 2**
- 6.0 COMPLETE CONTROL, FINAL ADJUSTMENTS - PHASE 3**
- 7.0 COATING DEFECTS - SECONDARY STRUCTURES INTERFERENCES**
- 8.0 CHECK AND MEASUREMENTS OF GROUNDING INSTALLATION - MEASUREMENTS OF PERMANENT INDUCED VOLTAGES**
- 9.0 REPORTS - SUPPLEMENTARY ACTIONS**

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 4/12

**REFERENCE DOCUMENTS**

Std Drawing No. STD-00-78-13  
[Cathodic Protection for Pipelines - Measuring Posts K1J, K1G]  
Std Drawing No. STD-00-78-15  
[Cathodic Protection for Pipelines - Measuring Posts K3S]  
Std Drawing No. STD-00-78-16  
[Cathodic Protection for Pipelines - Measuring Posts K3J, K3G / A&B]  
Std Drawing No. STD-00-78-17  
[Cathodic Protection for Pipelines - Measuring Posts K4 / A&B]  
Std Drawing No. STD-00-78-18  
[Cathodic Protection for Pipelines - Measuring Posts K4J, K4G / A&B]  
Std Drawing No. STD-00-78-19  
[Cathodic Protection for Pipelines - Measuring Posts K5]  
Std Drawing No. STD-00-78-20  
[Cathodic Protection Pipelines - Measuring Post K6]  
  
ELOT EN 12954  
[Cathodic protection of buried or immersed metallic structures - General principles and application for pipelines.]  
  
ELOT EN 13509  
[Cathodic protection measurement techniques]  
  
IEC 61936  
[Power installations exceeding 1kV A.C. common rules]  
  
prEN 50522  
[Earthing of power installations exceeding 1 kV a.c.]

**1.0**      **SCOPE**

This specification covers general instructions for setting in operation and commissioning of an Impressed Current Cathodic Protection System for the natural gas transmission pipeline.

The following requirements shall be satisfied (listed in order of precedence):

- a. This specification.
- b. **ELOT EN 12954** Cathodic protection of buried or immersed metallic structures - General principles and application for pipelines.
- c. **ELOT EN 13509** Cathodic protection measurement techniques

**2.0**      **GENERAL**

This specification covers measuring and inspection procedures, time schedule instructions for performance of measurements, measuring instrument specifications and instructions for compiling of reports.

In all phases of the commissioning, Contractor shall be aware, that dangerous induced voltages may occur on metallic equipment, electrically connected to the pipeline.

Contractor is responsible of using safe procedures to provide protection against induced voltages, including:

- Attaching all test leads first to the instrument and then to the structure to be tested. Leads shall be removed from structure first and from instrument last.
- Rubber boots or insulating gloves where direct contact with the structure is possible.

**3.0**      **ACTIONS BEFORE SETTING IN OPERATION**

After the pre-commissioning of the C.P. system and the verification of correct installation, Contractor must perform measurements and inspections.

The Contractor shall ensure that the test equipment used for obtaining each electrical measurement, is maintained in good operating condition, checked for accuracy, and is in compliance with the instrument specification given in this document.

During visible or audible thunderstorms Contractor must not perform any cathodic protection testing or work of similar nature, involving possible contact with the transmission pipe.

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 6/12

### **3.1 CHECK OF EACH MEASURING POST**

Contractor shall check the termination of the measuring cables in the terminal board at every measuring post for compliance with drawings and specifications.

Among other things the following shall be checked:

- Type of measuring post
- Mounting of cables
- Resistance of cables

The control of cable connections shall be performed with an ohmmeter. The resistance between the wires in the respective cables connected to the pipeline shall be measured and must practically not deviate from resistance of the wires (calculated or previous measured).

At measuring posts type K6, see **Std Drawing No. STD-00-78-20**, the resistance of insulating couplings (between terminals 3 and 4) shall be measured with an earth resistance meter, in order to determine the insulating effect of the couplings.

Electrical bondings between terminals that connect the two sections of the coupling must be removed. The resistance of the coupling must be greater than 10 Ohm.

At measuring post K4 and K5, see **Std Drawing No. STD-00-78-17-19**, the resistance between pipeline and casing (between terminals 1 or 3 and 7 or 8 and between 2 and 4) or secondary structure shall be measured with an earth resistance meter in order to determine any direct galvanic contact between pipeline and the secondary steel structure.

Finally, at measuring posts K3S, see **Std Drawing No. STD-00-78-15**, the sacrificial anodes shall be disconnected from the pipeline.

### **3.2 TEMPORARY CATHODIC PROTECTION**

All temporary cathodic protection systems that were used to protect the pipe during the construction phase shall be disconnected, and the pipe shall be unprotected for few days for depolarization.

### **3.3 NATURAL POTENTIAL MEASUREMENTS**

All the pipeline potential measurements shall be performed by connecting the positive (+) terminal of a DC-voltmeter to the pipeline (terminals 1 or 3) and the negative (-) terminal to a Cu/CuSO<sub>4</sub> reference electrode placed vertically over the pipeline.

To establish a good contact between the electrode and the electrolyte (soil), the reference electrode shall be pressed against the soil and, if necessary, the soil shall be watered.

If the top soil is frozen, Contractor shall assure that this layer is penetrated, in order to obtain a good contact between the reference electrode and the unfrozen soil.

Contractor shall assure that the reference electrode is completely filled with saturated copper sulfate and contains a sufficient amount of dissolved crystals.

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 7/12

In case of frosty weather the reference electrode must be kept frost-proof to avoid measuring errors.

The accuracy of the potential measurements shall be better than + 2.5%.

By measurement of the natural pipe-to-soil potential Contractor shall assure that anode beds and any other connections between the pipeline and soil are disconnected. The pipeline section in question must have been backfilled, reinsulated, and the welding finalized.

The natural potential shall then be measured with a digital voltmeter, class 1.5; internal resistance > 10 Mohm; measuring range 0-2 V.

The natural potential measures shall be within a range of approximately -300 to -800 mV. If larger fluctuations are ascertained, the results must be rejected due to a possible stray current influence. The source of the stray currents shall be determined, e.g. telluric currents, welding equipment, other CP-stations, induced high tension voltages, and the measurements repeated in the absence of the stray current influence.

### **3.4 PIPE RESISTANCE MEASUREMENTS**

The resistance measurements shall be performed with a DC-microvoltmeter, a DC-ammeter and a portable DC-current supply with an output current of approximately 1A.

The microvoltmeter is connected to the two inner line current measuring points (to be used for line current calculations, terminals 3,4, blue cables). The mutual distance between the points is 50 m.

A connection in series is established between the current supply and the ammeter, connected to the two outer current measuring points in the measured section (terminals 1,2, black cables, mutual distance 50.2m).

The resistance of the 50m section can be calculated from the measured voltage drop for an output of the current supply of 1A. Future line current measurements can be performed as voltage measurements.

Instruments to be used:

- DC ammeter class 1.5, measuring ranges 1 mA to 1 A and 1 mA to 5 A.
- DC micro voltmeter class 1.5, with zero indication or automatic polarity indication.

### **3.5 CHECK AND MEASUREMENTS ON C.P. STATIONS**

Contractor shall perform checks also at C.P. stations concerning the installation of cables and the measurement of the resistance of cables following the methodology described, in **para 3.1**.

Natural potential measurements shall take place using both a portable and the stationary reference electrode as in **para 3.3**. Contractor shall perform all the previously described checks and measurements (mounting of cables, resistance of cables, pipe resistance measurements etc).

Resistance between anode bed, stationary reference electrode, and pipeline shall be measured with an earth resistance meter.

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 8/12

Resistances to remote earth of anode bed and auxiliary earth shall be measured with an earth resistance meter by the "three electrode alternating current method" according to **IEC 61936** and **prEN 50522**. The probe distance for the auxiliary probe shall be more than 40m. The following resistance criteria must be followed:

Resistance, auxiliary earth/remote earth	< 100 Ohm
Resistance, anode bed/remote earth	< 10 Ohm
Resistance, anode bed/pipeline	< 10 Ohm
Resistance, of the Cathode cables	< 2 Ohm
Resistance, stationary reference electrode/Pipeline	< 10 Ohm

**3.6 REPORTS**

The measured results shall be recorded on forms which shall be submitted to Supervision. Also a diagram for each section showing the longitudinal change of natural potential and pipe resistance from post to post shall be drawn in order to show the change of the values along the pipeline.

**4.0 START-UP OF THE C.P. SYSTEM - PHASE 1**

Before setting in operation the system Contractor shall assure that all the above measurements prove the satisfactory installation of the system.

Upon completion of these measurements, a preliminary setting in operation of the C.P. system shall be performed by manually adjustment of the rectifier, so that the "ON"- potential at the drain point is between -1.3 V and -1.5 V and "ON"-potential is reached at the edges of the pipeline section more negative than -1.0 V.

After an adequate period of polarization (normally 24 hours), "ON-OFF" potential measurements shall be performed at "critical" points of the route (see **para 4.3.**), such as locations where larger deviations in the natural pipe-to- soil potential occur, at bored crossings and at the end of the range of the protection system.

The rectifiers shall be re-adjusted if necessary until the pipe - to - soil potential, required for complete cathodic protection, is obtained in accordance with the following criteria.

Protection Potential Criteria:

"ON" - potentials	-1000 to -1600 mV
"OFF"- potentials (<50°C)	< -850 mV
"OFF"-potentials (>50°C)	-850 to -1150mV

On pipelines with elevated temperatures (>50°C) "OFF" potential more negative - 1150 mV may cause stress corrosion.

**4.1 "ON" AND "ON-OFF" POTENTIAL MEASUREMENTS**

**4.1.1 "ON" POTENTIAL MEASUREMENTS**

Measurement of the "ON"-potential shall be performed as in **para 3.3**, but with the protective current applied constantly.

#### **4.1.2 "ON-OFF" POTENTIAL MEASUREMENTS**

In order to obtain the true protective potential called the "OFF"-potential a time relay shall be installed in the cathode cable at the C.P. station on the protected section,

interrupting the current for 3 to 5 sec., within a period of 60 sec.

The "ON-OFF"-potentials shall be determined by an analog DC voltmeter recorder with a periodic damping class 1.5 internal resistance >10 Mohm, measuring range 0-2 V, response time < 1 second.

The "OFF"-potential shall be determined within the first second of the "OFF"-period, and the "ON"-potential at the the end of the "ON"- period.

#### **4.2 MEASUREMENTS ON THE C.P. STATION**

At the C.P. station the following measurements must be carried out and reported.

Output Voltage D.C.

"ON-OFF"-potential, stationary reference electrode/ pipeline

"ON-OFF"-potential, portable reference electrode/ pipeline

Protective current via the Ammeter readings.

Calculated protective current (from the 50m calculated resistance method see para 3.4.).

Direct interference measurements at all secondary structures which are less than 100 m from the anode bed, if any, according to para 4.2.1.

#### **4.2.1 DIRECT INTERFERENCE MEASUREMENTS**

Direct interference measurements on secondary structures less than 100m from the anode bed shall be performed as a potential measurement in accordance with para 4.1.2.

#### **4.3 MEASUREMENTS TO BE CARRIED OUT AT THE MEASURING POSTS**

Measurements at all K1, K4, K5, K6, K8, K9 and at a random 25% of K3 measuring posts shall be carried out in accordance with the following:

- "ON"-potential measurements (see para 4.1.1.)
- "ON-OFF"-potential measurements (see para 4.1.2.)
- 50m pipe resistance and calculated current with voltage and compensation method as in para 4.3.1.
- Resistance pipeline/casing.

#### **4.3.1 50 M RESISTANCE-CURRENT MEASUREMENTS**

##### **4.3.1.1 VOLTAGE METHOD**

By the voltage method, the voltage drop over the two inner measuring points (terminals 3,4 blue cables), shall be measured in the "ON"- state.

From the pipe resistance and the voltage drop the line current shall be calculated.

**Job Spec. No** 799/6  
**Revision** 0  
**Date** 05-04-2011  
**Page** 10/12

**4.3.1.2 COMPENSATION METHOD**

By the compensation method a compensation current opposing the line current is adjusted in the "ON"-state in such a way that the voltage drop over the two inner measuring points is 0 micro volts. The line current equals the compensation current.

**4.4 SACRIFICIAL ANODES**

After the completion of the adjustment of the C.P. system, the Engineer shall decide which of the sacrificial anodes shall be connected to the pipeline by bonding the terminals 9 and 11 with 10 and 12 at measuring post type K3S, see **Std Drawing No. STD-00-78-15**.

**4.5 REPORTS**

For all the above measurements reports and diagrams shall be performed as in para 3.6. A diagram shall also be provided showing the measured protective current at each post.

**5.0 CONTROL MEASUREMENTS - PHASE 2**

The complete control measurement in phase 2 (4 to 6 months after phase 1) comprises.

- a) Same measurements as in para 4.3 at phase 1 followed by eventual readjustment of the rectifiers.
- b) Measurements at C.P. stations in accordance with **para 4.2**.
- c) Measurements at every measuring post according to the required measurements for each type of measuring posts (see **Job Spec. No. 799/2**).
- d) Two-reference cell interference measurements with normal current output at every measuring post, secondary pipeline and major power and telephone cable crossing, in accordance with **para 5.1**.
- e) Two-reference cell interference measurements in the vicinity of the anode beds in accordance with **para 5.1**.
- f) Direct interference measurements at all secondary structures which are less than 100 m from the anode bed, if any, according to **para 4.2.1**.

**5.1 TWO-REFERENCE CELL INTERFERENCE MEASUREMENTS**

Two-Reference cell, interference Measurements shall be performed as followed:

A reference cell connected to the negative analogue voltmeter recorder (class 1.5 internal resistance > 10 M $\Omega$ , measuring range 0-2 V) terminal shall be placed vertically above the transmission line. Two reference cells, placed at a distance of 10 m perpendicular to the transmission line to both sides, shall alternately be connected to the positive voltmeter terminal.

The difference between the potential values read in "ON"-state and the "OFF"-state gives the change in the voltage gradient and thus the interference level.

Job Spec. No 799/6  
Revision 0  
Date 05-04-2011  
Page 11/12

**5.2 REPORTS**

For all the above measurements reports and diagrams shall be performed as in **para 4.1.3.**

**6.0 COMPLETE CONTROL. FINAL ADJUSTMENTS - PHASE 3**

Except for the interference measurements, phase 3 (8 to 12 months after phase 2) is a repetition of phase 2. Line currents shall be measured by the voltage method only.

**7.0 COATING DEFECTS - SECONDARY STRUCTURES INTERFERENCES**

In all three phases the longitudinal diagrams and curves of "ON" and "OFF" potential, protective current e.t.c. may indicate coating defects or interferences from metallic secondary structures. Contractor is responsible to investigate for the specific point with the damaged coating (by using holiday detectors), and make all the required repairs to the coating.

Interferences of a metallic structure can be determined by the following criteria:

- Direct interference measurements:

a) Current discharge points

Steel structures : Potential change > 20 mV in the positive direction of the structure -to - soil potential.

b) Current entry points

Lead structures : Structure-to-soil potential < -2.5V.

Aluminum structures : Structure-to-soil potential < -1.2V

The potential change does not include the IR-drop so the guideline is a potential difference > 100 mV including the IR-drop.

Two reference cell measurements:

a) Current discharge points

All structures : Potential change > 20 mV in the positive direction of the structure -to - soil potential.

**8.0 CHECK AND MEASUREMENTS OF GROUNDING INSTALLATION - MEASUREMENTS OF PERMANENT INDUCED VOLTAGES**

The measurement shall be carried out in conjunction with the commissioning phase 1 and phase 3.

Instruments to be used on pipelines influenced by high voltage transmission lines shall have sufficient alternating current rejection (>90 dB for 50 Hz signals) to provide accurate direct current data.

**8.1 PHASE 1**

The following measurements shall be carried out in order to prove the efficient function of the installed permanent earthing system.

a. Measurements for all cable connections. As per **para 3.1.**

b. Measurements for each discharge voltage arrester.

**Job Spec. No 799/6**  
**Revision 0**  
**Date 05-04-2011**  
**Page 12/12**

c. Measurements of the leakage resistance of each earthing installation to remote earth. Measurements by the "three-electrode alternating current

method" with an earth resistance meter in accordance with IEC 61936 and prEN 50522.

d. Measurements of the voltage difference between pipeline and earth at every measuring post in proximity area (Measuring posts type K1G, K3G and K4G as per **Std Drawings No. STD-00-78-13, 16 and 18** terminals 5 and 6).

**8.2 PHASES 2 AND 3**

A repetition of phase 1 items b, d.

**8.3 RESULTS - REPORTS**

The results of the above inspection shall be recorded in the forms of the measuring posts.

**9.0 REPORTS - SUPPLEMENTARY ACTIONS**

In all phases Contractor shall handover to Supervision the above requested reports and diagrams, for information, review and comments on the C.P. system.

Any supplementary action (if any) to fulfill the Cathodic Protection Criteria, shall be approved by Supervision after full information by Contractor (including measurements and reports).