



**HELLENIC GAS
TRANSMISSION
SYSTEM OPERATOR**

357-359, MESSOGION AVE.,
115 25 ATHENS, GREECE
Tel.: 210 6501258
Fax : 210 6501551

**TECHNICAL JOB
SPECIFICATION**

835/1

REVISION 0

DATE 05/04/2011

HIGH PRESSURE (HP) TRANSMISSION SYSTEMS

PLANT APPLIED INTERNAL EPOXY LINE PIPE COATING

Job Spec. No 835/1
Revision 0
Date 05-04-2011
Page 2/7

QUALITY ASSURANCE PAGE

CHANGES LOG

REVISIONS LOG

0	05-04-2011	FIRST ISSUE	PQ DPT	VG
Rev. No	Rev. Date	REASON FOR CHANGE	Made By	Approved By

CONTENTS

REFERENCE DOCUMENTS

- 1.0 SCOPE
- 2.0 GENERAL REQUIREMENTS
- 3.0 SURFACE PREPARATION
- 4.0 COATING MATERIALS AND APPLICATION
- 5.0 TESTING
- 6.0 MARKING
- 7.0 HANDLING, STORAGE AND TRANSPORT
- 8.0 TECHNICAL DOCUMENTATION

Job Spec. No	835/1
Revision	0
Date	05-04-2011
Page	4/7

REFERENCE DOCUMENTS

ELOT EN 10301

[Steel tubes and fittings for on and offshore pipelines - Internal coating for the reduction of friction for conveyance of non corrosive gas]

ELOT EN ISO 8501-1

[Preparation of steel substrates before application of paints and related products - Visual assessment of surface cleanliness - Part 1: Rust grades and preparation grades of uncoated steel substrates and of steel substrates after overall removal of previous coatings]

1.0 **SCOPE**

1.1 **ITEM**

This specification defines the minimum requirements for the surface preparation, coating application, inspection and handling of plant-applied internal epoxy coating of line pipes.

Primary objective of the coating is to reduce frictional losses and thereby improve pipeline transport capacity.

Secondary benefits are to reduce internal corrosion and fouling during storage and construction, and to facilitate later cleaning operations.

The coating shall be liquid epoxy type and shall be selected according to **ELOT EN 10301**.

1.2 **SERVICE TEMPERATURE**

The service temperature of the pipeline will be from -15°C to +50°C. However, coated pipes may be stored at temperatures down to -20°C and with a surface temperature up to 80°C in the sun.

2.0 **GENERAL REQUIREMENTS**

2.1 **GENERAL**

A record of pipe serial numbers shall be kept for the Owner's information. This record shall contain all information on the delivered pipes, i.e. lengths, damages, cuts, repairs, transfer of serial numbers, coated stock, bare stock, scrap.

These records shall be available at all times for review by the Owner's Representative. At the completion of coating operations the Contractor shall satisfactorily account for all materials or shall reimburse the Owner for the full cost of any materials not so accountable.

All coating materials, production and repair procedures as well as test methods shall be approved by the Owner or his substitute before coating starts.

Coating application procedures shall be documented and monitored by the Contractor. Written records shall be maintained by qualified personnel.

The procedures shall include:

- Surface preparation, including grades and types of abrasive, removal of steel defects, cleanliness, surface profile and methods of measurement.
- Complete details of the coating materials, together with quality control and Contractor's certification sheets and materials storage, which shall be in accordance with the Manufacturer's recommendations.
- Application of coating, including details of application temperatures, curing times and methods, and acceptable prevailing working conditions (humidity, dust and temperature).
- Inspection and testing, including instrument and equipment types, makes and uses.
- Details of instrument and equipment calibration methods, including relevant standards and examples of calibration certificates.
- Coating defect repair methods and materials.

2.2 STANDARDS AND RECOMMENDATIONS

Coating shall conform to **ELOT EN 10301**, **ELOT EN ISO 8501-1** and the requirements specified herein.

3.0 SURFACE PREPARATION

The internal surface shall be cleaned, shot-blasted and subjected to dust removal in accordance with **ELOT EN 10301**.

The resulting surface finish shall conform to SA 2 1/2 according to **ELOT EN ISO 8501-1**.

The surface profile measured from peak to trough shall be in the range 25-50 µm.

4.0 COATING MATERIALS AND APPLICATION

In accordance with **ELOT EN 10301**. Contractor's recommendations concerning storage, handling, use of materials shall be followed.

Prior to the commencement of full production the Contractor shall carry out a qualification test on lengths of line pipe to be coated to demonstrate that the coating applied in accordance with the Contractor's proposed procedures will comply with the requirements of this specification.

The pipes shall be coated on a continuous coating line without any risk of damage to the pipe (external pipe wall, bevels and coating) during the various heating, coating, curing and quenching operations.

Dry film thickness shall be minimum 60 µm and maximum 150 µm.

All weld preparations and a distance of 20 mm from each pipe end shall be free of coating. These parts may either be protected before application or the coating may subsequently be removed.

5.0 TESTING

5.1 GENERAL

An office and all necessary facilities required for the performance of his work shall be made available to the Owner's Representative by the Contractor.

Inspection shall be carried out by the Contractor and, unless otherwise agreed, in the presence of the Owner's representative.

Methods, frequencies and acceptance criteria as per **ELOT EN 10301** and as specified below. Any test not fulfilling specified requirements shall constitute that all pipes represented by the failed test specimen be rejected.

5.2 SURFACE PREPARATION

Each pipe shall be visually inspected to verify cleanliness after blast cleaning.

5.3 PIPE ENDS

The cutback length and the absence of coating on weld preparations and pipe-ends shall be inspected regularly, at least once per shift.

6.0 MARKING

The identification of the pipes shall be guaranteed during coating.

Any internal identification markings shall be carefully recorded before surface preparation begins, and shall be repeated on the completed coating with weather resistant paint of a contrasting colour, unless otherwise agreed with the Owner's

Job Spec. No 835/1
Revision 0
Date 05-04-2011
Page 7/7

Representative.

7.0 HANDLING, STORAGE AND TRANSPORT

In addition to fulfilling the requirements of **ELOT EN 10301**, all procedures for handling, storage, and transportation shall be approved by the Owner.

Care shall be taken to prevent damage to the pipe.

Externally coated pipe may, under no circumstances be dragged, or rolled over the ground.

When handling the pipes non-metallic slings, spreader bars, protected hooks, etc, shall be used. Large diameter pipe shall preferably be transported by the use of vacuum spreader beams.

The pipes shall be stored on even and firm ground and be placed on wooden supports which keep the pipes clear of the ground and in such a way that water and mud cannot accumulate inside the pipe. The pipes shall be self-draining.

Supports and stacking shall be according to approved drawings/procedures.

The coated pipe shall be stacked in such a manner that any external coating does not contact a hard surface, which may damage the coating.

During transportation the pipes shall be stacked and secured such that they cannot be damaged (abrasion, penning). **ELOT EN 10301** shall be taken into consideration concerning transportation.

All coated pipes ready for transportation shall be provided with end caps. The pipes must be dry inside before mounting the caps.

Stockpiling of externally coated pipes shall be made so as to avoid any deterioration of the polyethylene coating. In particular, the coated pipes shall, if necessary, be shielded from the harmful effects of ultraviolet rays.

8.0 TECHNICAL DOCUMENTATION

8.1 WITH TENDER

Raw material Suppliers' data sheets.

Written quality assurance procedures, standard operating procedures, and repair procedures.

Request for approval of coating materials, production and repair procedures as well as test methods not otherwise defined.

Statement of temperature of pipe surface at time of application.

Statement of maximum permissible in-service temperature of coating, if higher than +50°C.

8.2 AFTER AWARD OF CONTRACT

Records of performance testing as per **ELOT EN 10301**.

8.3 ON DELIVERY

Manufacturer's Certified Test Report, i.e. certified by Manufacturer's Authorized Representative, independent from the manufacturing department, containing the results of performed production testing.

Pipes shall be referred to by their pipe mill assigned numbers.