



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 1 of 16


HIGH PRESSURE (HP) TRANSMISSION SYSTEMS

PLANT COATING OF BURIED VALVES FOR PIPELINE

APRIL 2020

This document is the property of DESFA S.A. and shall not be reproduced, copied or used for any purpose, other than for which it is specially furnished

| | | | | | |
|------------|--------------------|-------------|-------------|-------------|-------------|
| | | | | | |
| 1 | Second Issue | 30-06-2021 | MP | DK | TPI |
| 0 | First Issue | 05-04-2011 | PQ DPT. | | V.G. |
| REV | DESCRIPTION | DATE | PRPD | CHKD | APVD |



Doc No: DSF-SPC-MEC-009

Rev. 1

Page 2 of 16

[illegible]



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION


Doc No: DSF-SPC-MEC-009

Rev. 1

Page 3 of 16

Table Of Contents

| | | |
|----|---------------------------------------|----|
| 1 | INTRODUCTION | 4 |
| 2 | SCOPE AND OBJECTIVES..... | 4 |
| 3 | REFERENCES | 4 |
| 4 | ACRONYMS | 5 |
| 5 | GENERAL REQUIREMENTS | 5 |
| 6 | MATERIALS | 6 |
| 7 | SURFACE PREPARATION | 7 |
| 8 | COATING APPLICATION | 8 |
| 9 | INSPECTION AND TESTING | 8 |
| 10 | REPAIRS..... | 10 |
| 11 | MARKING..... | 11 |
| 12 | HANDLING, STORAGE AND TRANSPORT | 12 |
| 13 | TECHNICAL DOCUMENTATION | 12 |

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 4 of 16 |

1. INTRODUCTION

2. SCOPE AND OBJECTIVES

2.1 ITEM

This specification specifies the minimum requirements for the surface preparation, coating application, inspection and testing of a two component polyurethane coating of buried valves of gas pipeline to be executed in shop.

2.2 SERVICE TEMPERATURE

The service temperature of the pipeline will be from -15°C to +50°C. Contractor shall take also into consideration the fact that for a short time very low temperature of -40°C might occur. However, coated valves may be stored at ambient temperatures down to -20°C and with a surface temperature up to 80° C under the sun.

3. REFERENCES

3.1 Reference Documents

- Job Specification DSF-SPC-PIP-025 [Ball Valves DN > 50]

3.2 Reference Codes and Standards

- **EN 10288** - Steel tubes and fittings for onshore and offshore pipelines - External two layer extruded polyethylene based coatings
- **EN 10289** - Steel tubes and fittings for onshore and offshore pipelines - external two layer extruded polyethylene based coatings
- **EN 10290** - Steel tubes and fittings for onshore and offshore pipelines - External liquid applied polyurethane and polyurethane-modified coatings



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 5 of 16

- **EN 10290** [Steel tubes and fittings for onshore and offshore pipelines - External liquid applied polyurethane and polyurethane-modified coatings]
- **EN ISO 2808** [Paints and varnishes - Determination of film thickness]
- **EN ISO 8501-1** [Preparation of steel substrates before application of paints and related products - Visual assessment of surface cleanliness - Part 1: Rust grades and preparation grades of uncoated steel substrates and of steel substrates after overall removal of previous coatings]
- **EN ISO 8502-2** Preparation of steel substrates before application of paints and related products - Tests for the assessment of surface cleanliness - Part 2: Laboratory determination of chloride on cleaned surfaces
- **EN ISO 8503-2** [Preparation of steel substrates before application of paints and related products - Surface roughness characteristics of blast-cleaned steel substrates - Part 2: Method for the grading of surface profile of abrasive blast-cleaned steel; comparator procedure]
- **EN ISO 8504-2** [Preparation of steel substrates before application of paints and related products - Surface preparation methods - Part 2: Abrasive blast-cleaning]

All standards or codes mentioned in this specification are valid in their latest version or by the relative superseded edition.


4. ACRONYMS

5. GENERAL REQUIREMENTS

5.1 GENERAL

All coating materials, production and repair procedures as well as test methods shall be approved by the Owner or the Owner's Representative before coating starts.

Coating application procedures shall be documented and monitored by the Contractor. Written records shall be maintained by qualified personnel.

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 6 of 16 |

The procedures shall include:

- Complete details of the coating materials, together with quality control and Contractor's certification sheets, and of materials storage, which shall be in accordance with the Contractor's recommendations;
- Surface preparation, including number, type and size of cleaning machines, grades and types of abrasive, removal of steel defects, cleanliness, surface profile and methods of measurement;
- Application of coating, including details of application temperatures, curing times and methods, cutback and beveling methods and acceptable prevailing working conditions (humidity, dust and temperature);
- Inspection and testing, including instrument and equipment types, makes and uses;
- Details of instrument and equipment calibration methods, including relevant standards and examples of calibration certificates;
- Coating defect repair methods and materials.
- Storage, handling and transport procedures.

A record of valves serial numbers shall be kept for Owner's information. This record shall contain all information on the delivered valves, i.e. types, damages, repairs, transfer of serial numbers.


These records shall be available at all times for Owner's Representative review. At the completion of coating operations, the Contractor shall satisfactorily account for all materials or shall reimburse the Owner for the full cost of any materials not balanced.

6. MATERIALS

The coating material and cured coating film shall be of two component polyurethane and shall meet the requirements of **EN 10290**, Class B, type 3 (-20 TO 80 , TYPE 2 IS FOR -20 TO 60).

The Contractor shall provide all information described in paragraph 13.

Prior to the commencement of the coating works the Contractor shall carry qualification tests to demonstrate that the polyurethane coating is in accordance with requirements of this specification.

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 7 of 16 |

The test program, which shall be witnessed by the Owner, shall be based on the application of the coating to two valves and to three test panels.

The test requirements are summarized in Table 1 and shall be submitted to the Owner for approval.

7. SURFACE PREPARATION

All preparation and coating works shall be carried out in a fully enclosed weatherproof workshop.

Valves, which have not been coated within three hours, shall be reblasted.

Blast cleaning shall be suspended if the valves surface temperature drops 3° C below the dew point.

The valves surface shall be dried before blast cleaning.

All weld spatter, grease, oil, etc. shall be removed prior to blasting.


The ends of the valves shall be protected with plugs to prevent entry of the abrasive into the valve during the blast cleaning.

Unless otherwise agreed, surfaces shall be cleaned by abrasive blasting to at least degree SA 2 1/2 according to **EN ISO 8501-1**. Angular sharp grit or a mixture of grit and shot shall be used. Shot applied alone is not be accepted. Blast cleaning abrasives shall be agreed with the Owner.

The use of sand is not permitted. After blast cleaning, the surface profile shall have an average peak to trough height of 50 µm and a maximum of 90 µm. This shall be measured in accordance to **EN ISO 8503-2** or other method approved by the Owner. Dust on the valve exterior shall be removed directly before coating by a method which is approved by the Owner, for example compressed dry air followed by vacuum cleaning.

Abrasive materials shall be employed in accordance with **EN ISO 8504-2**.

Blasting abrasives shall be kept dry, clean and free from contamination. Airlines shall be filtered to remove oil and moisture. Blasting abrasive shall be cleaned by a dust extraction system, which removes fine particles the size of which will be determined after the initial site testing.

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 8 of 16 |

When recovered metallic grit systems are used, a stabilized working mix of blast cleaning material shall be established and maintained throughout the entire course of the production by frequent small additions from fresh or cleaned stock at a rate sufficient to replenish consumption. Large additions of new material shall be avoided. Report verifications of the mix quality shall be submitted to Owner by the Contractor.

Blasting and other dust producing areas shall be kept separate from coating application areas. The blast-cleaned surface shall not be contaminated with dirt, dust, metal particles, hydrocarbons, water or any other foreign matter, which are detrimental to the coating.

8. COATING APPLICATION

The coating will be applied with hot airless spray from a machine where the material components are mixed within the spray head.

The machine shall be equipped with adequate filters to avoid intuition of foreign substances or other particles.

The wet film will be monitored by using suitable metal comb gunges to ensure that the required dry film thickness will be achieved. The number of over coats shall be such to obtain a total thickness of 1500 microns.

The coating works shall proceed when ambient temperature is above 5°C, the relative humidity is below 85% and the surface to be coated is at least at temperature 3°C above the dew point of the surrounding atmosphere during all time of the coating operation.

The finished coating shall be left off at valve ends for a length of 150 mm ± 15 mm, in order welding of the valve to the pipeline will be performed without damage to the coating.

9. INSPECTION AND TESTING

9.1 GENERAL

An office and all necessary facilities required for the performance of his work shall be made available to the Owner's Representative by the Contractor.



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 9 of 16

Inspection and testing shall be carried out by the Contractor and, unless otherwise agreed, in the presence of the Owner's Representative.

Inspection activities shall be as follows:

- Inspection of surface cleaning.
- Visual inspection.
- Inspection of coating thickness.
- Inspection of coating adhesion.
- Holiday testing.

Inspection and testing requirements are summarized in Table 2.

9.2 SURFACE CLEANING

All surfaces shall be free from dust or chloride contamination. Three items shall be tested at random per shift for surface contamination in accordance to **EN ISO 8502-2** and **EN ISO 8501-1**. No surface shall have in excess of 2µg/cm² chloride.

9.3 VISUAL INSPECTION

Every valve shall be visually inspected. The coating shall be continuous and free of blisters, pinholes, scratches or any other irregularities and shall be of uniform colour and gloss.

9.4 COATING THICKNESS

Coating thickness shall be measured using non-destructive instrument approved by the Owner and in accordance with **EN ISO 2808**. Instruments shall be calibrated at least once per 8 hour period or work shift, whichever is the shortest period.

Wet film thickness checks shall be carried out as spraying progresses in accordance with **EN ISO 2808**, Method 7B. Dry film thickness checks shall be carried out on the cured coating in accordance with **EN ISO 2808**, Method 6. Three sets of thickness measurements shall be made on each valve.

Each set of measurements will consist of four readings at equidistant points around the valve. The average value of each set of four measurements shall comply with the specified



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 10 of 16

minimum coating thickness and no individual reading shall be less than 75% of the minimum thickness.

9.5 COATING ADHESION

One valve from each shift or per 5 valves, whichever is the more frequent, shall be tested for adhesion of the coating. The coating adhesion at a randomly selected location on the item shall be determined by the following method.

Using a heavy-duty short-bladed knife two incisions of approximately 15mm in length shall be made in the coating. The incisions shall fully penetrate the coating through to the steel surface and shall cross through each other to form an "X" with an angle of intersection of approximately 30 degrees. Commencing at the intersection, an attempt shall be made to lift the coating from the steel substrate using the blade of the knife.

Peel-away from the point of intersection of more than the critical dimension or brittle breakaway of flakes of more than the critical dimension in size, shall be deemed a failure. The critical dimension shall be 2 mm unless specified otherwise by the Owner. Cohesive failures, caused by voids leaving a honeycomb structure on the surface, shall be deemed a failure.


9.6 POROSITY TESTING

The Contractor shall (holiday) detect porosity 100% of the coated surface in accordance with **EN 10290**. The testing shall be carried out by means of a high voltage holiday detector supplied by the Contractor of a type approved by the Owner.

According to **EN 10290** the test voltage shall be set at 8 kV/mm of measured thickness, but the maximum allowable test voltage is 20 kV.

10. REPAIRS

All damages to polyurethane coating shall be repaired. Valves with coating defect greater than 50 cm² (in total) shall be rejected to complete stripping and recoating. All repairs to the coated valves shall be made at Contractor's expenses.

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 11 of 16 |

A coating system compatible with the original and having identical characteristics shall be used.

10.1 CLEANING

The damaged area shall be cleaned of foreign bodies and loose bits of polyurethane material.

The surface shall be cleaned by abrasing of the exposed metal to at least degree SA 2 1/2 according to **EN ISO 8501-1** and roughening of the surrounding coating will be achieved.

10.2 APPLICATION OF COATING

The appropriate number of coats shall be applied in order to achieve the specified coating thickness, using material and procedures approved by the Owner. If required, Contractor shall perform a procedure test in the presence of the Owner's Representative.


10.3 INSPECTION OF THE REPAIRED AREA

The repaired area shall be holiday tested according the requirements of paragraph 9.6 in order to verify the successful coating work.

11. MARKING

Each package of coating materials shall include the following marking:

- Contractor's name.
- Premises of Contractor.
- Production batch number.
- Time limit for use.
- Any special safety or storage instructions relevant to the batches.
- Condition of application of any repair product.

| | | |
|---|--|------------------------------------|
|  | Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr | TECHNICAL SPECIFICATION |
| Doc No: DSF-SPC-MEC-009 | Rev. 1 | Page 12 of 16 |

Valves are marked on the welding ends, which shall be left uncoated, uncoated length shall be 150 mm from valve ends.

12. HANDLING, STORAGE AND TRANSPORT

Instruction regarding handling, storage and transportation of valves are referred in Job Specifications listed in "Reference Documents".

When handling the valves non- metallic slings spreader bars or protected hooks shall be used. The coated valves shall be moved in such a manner that the existing coating is not in contact with a hard surface, which may damage the coating.

Storage of coated valves shall be executed in such a manner to avoid any deterioration of the polyurethane coat.

13. TECHNICAL DOCUMENTATION

13.1 WITH TENDER

Contractor shall submit the following:

- Raw material Contractor's data sheets, including health and safety data, viscosity relative density, mixing ratio, pot life and flash point.
- Written quality assurance procedures, standard operating procedures and repair procedures.
- Request for approval of coating materials, production and repair procedures as well as test methods not elsewhere defined.

13.2 AFTER AWARD OF CONTRACT

Results of all test of the coating material as defined in this specification. The tests shall be in accordance with the requirements of **EN 10290** and shall include the following:

- a) Impact strength.
- b) Indentation resistance.
- c) Flexibility.
- d) Elongation at break.



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 13 of 16

- e) Coating resistivity.
- f) Heat reversion.
- g) Cathodic disbonding.

13.3 ON DELIVERY

Contractor's Certified Test Report, i.e. certified by Manufacturer's Authorized Representative, independent from the manufacturing department, containing the results of performed prequalification and production testing and other requirements in this specification.

The following tests shall have been witnessed by the Owner's Representative: Surface profile, coating thickness, holiday detection, and adhesion tests.

Raw material certificates for each batch of materials used.



Hellenic Gas Transmission System Operator S.A.
 357-359 Messogion Av., GR 152 31 Halandri
 Tel.: 213 088 4000
 Fax: 210 674 9504
 Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 14 of 16

TABLE 1

INSPECTION SUMMARY FOR PROCEDURE QUALIFICATION TEST

| Work Stage | Relevant Paragraph | Acceptable Values | No. of Tests |
|--|--------------------|--|-----------------|
| <u>Before Cleaning</u> | 7 | No indication of oil contamination | All valves |
| • Oil Contamination | | | |
| <u>After Cleaning</u> | | | |
| • Cleanliness | 7 | Sa 2 1/2 | All valves |
| • Profile | 7 | 50 - 90 µm | All valves |
| • Chloride | 7 | 2 µg/cm ² | All valves |
| • Dust and Oil | 7 | No indication of dust or oil contamination | All valves |
| <u>Finished Coating</u> | | | |
| • Coating Thickness | 8 | 1500 µm (min) | All valves |
| • Coating Adhesion | 9.5 | 2 mm max | (2x4 per valve) |
| • Holidays | 9.6 | No holidays | All valves |
| • Visual Examination | 9.3 | Continuous, uniform colour, free from blisters, pinholes, scratches and irregularities | All valves |
| • Cut Backs | 8 | 150 ±15mm | All valves |
| <u>Finished Coating on Test Panels</u> | | | |
| • Impact Strength | 6 | | 3 test panels |
| | 6 | | |



Hellenic Gas Transmission System Operator S.A.
 357-359 Messogion Av., GR 152 31 Halandri
 Tel.: 213 088 4000
 Fax: 210 674 9504
 Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 15 of 16

| | | | |
|--------------------------|-----|-------------------------------------|--|
| • Indentation Resistance | | | |
| • Flexibility | 6 6 | As per coating material data sheets | Each test panel may be used for more than one test |
| • Elongation at break | 6 | | |
| • Coating Resisitivity | 6 | | |
| • Heat Reversion | 6 6 | | As per EN 10290 |
| • Cathodic Disbanding | | | |
| • CO ₂ | 6 | | |
| • Heat reversion/aging | | | |

TABLE 2

INSPECTION SUMMARY FOR PRODUCTION TEST

| Work Stage | Relevant Paragraph | Acceptable Values | No. of Tests |
|-------------------------|--------------------|---|-----------------|
| <u>Before Cleaning</u> | | | |
| • Oil Contamination | 7 | No indication of oil contamination | All valves |
| <u>After Cleaning</u> | | | |
| • Cleanliness | 7 | Sa 2 1/2 | All valves |
| • Profile | 7 | 50 - 90 µm | All valves |
| • Chloride | 7 | 2 µg/cm ² | 3 per Shift |
| • Dust and Oil | 7 | No indication of dust or oil contamination | All valves |
| <u>Finished Coating</u> | | | |
| • Coating Thickness | 8 | 1500 µm (min) | |
| • Coating Adhesion | 9.5 | 2 mm max | |
| • Holidays | 9.6 | No holidays | All valves |
| • Visual Examination | 9.3 | Continuous, uniform colour, free from blisters, pinholes, | (2x4 per valve) |
| | | | All valves |
| | | | All valves |



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-MEC-009

Rev. 1

Page 16 of 16

| | | | |
|-------------|---|------------------------------|------------|
| • Cut Backs | 8 | scratches and irregularities | All valves |
|-------------|---|------------------------------|------------|