



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-PIP-035

Rev. 1

Page 1 of 7

HIGH PRESSURE (HP) TRANSMISSION SYSTEMS

GASKETS

JUNE 2021

This document is the property of DESFA S.A. and shall not be reproduced, copied or used for any purpose, other than for which it is specially furnished

1	Second Issue	30-06-2021	MP	KM or DK	TPI
0	First Issue	05-04-2011	PQ DPT.		V.G.
REV	DESCRIPTION	DATE	PRPD	CHKD	APVD



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION


Doc No: DSF-SPC-PIP-035

Rev. 1

Page 3 of 7

Table of Contents

REFERENCES DOCUMENTS.....	4
1. SCOPE	5
2. GENERAL REQUIREMENTS	5
3. SUPPLEMENTARY REQUIREMENTS.....	ERROR! BOOKMARK NOT DEFINED.
4. TECHNICAL DOCUMENTATION	ERROR! BOOKMARK NOT DEFINED.
5. INSPECTION AND CERTIFICATION.....	ERROR! BOOKMARK NOT DEFINED.

 <p>Hellenic Gas Transmission System Operator S.A. 357-359 Messogion Av., GR 152 31 Halandri Tel.: 213 088 4000 Fax: 210 674 9504 Email: desfa@desfa.gr</p>	TECHNICAL SPECIFICATION
Doc No: DSF-SPC-PIP-035	Rev. 1 Page 4 of 7

REFERENCES DOCUMENTS

Job spec. DSF-SPC-QAC-005

[shop inspection of equipment and material for NGTS projects]

Elot EN 10204

[inspection documents for metallic products]

Elot EN 12560-1 [flanges and their joints. Gaskets for class-designated flanges. Non-metallic flat gaskets with or without inserts]

Elot EN 12560-2 [flanges and their joints. Gaskets for class-designated flanges. Spiral wound gaskets for use with steel flanges]

Elot EN 12560-3 [flanges and their joints. Gaskets for class-designated flanges. Non-metallic ptfе envelope gaskets]

Elot EN 12560-4 [flanges and their joints. Gaskets for class-designated flanges. Corrugated, flat or grooved metallic and filled metallic gaskets for use with steel flanges]

Elot EN 1591-1 (harmonized with EU directive 2014/68/EU- PED)

[flanges and their joints - design rules for gasketed circular flange connections - part 1: calculation method]

Elot EN 1759-1 [flanges and their joints. Circular flanges for pipes, valves, fittings and accessories, class-designated. Steel flanges, NPS 1/2 to 24]

Elot en 10088-3

[stainless steels - part 3: technical delivery conditions for semi-finished products, bars, rods, wire, sections and bright products of corrosion resisting steels for general purposes]

All standards or codes mentioned in this specification are valid in their latest version or by the relative superseded edition.



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-PIP-035

Rev. 1

Page 5 of 7

1. SCOPE

1.1 ITEM

Gaskets for pipe flanges.

1.2 SERVICE

Sweet natural gas with sporadic passage of water and glycol.

1.3 ADDITIONAL INFORMATION

Additional information may be given in the Material Requisition and should be read in conjunction with this material specification.

Any conflict between requirements of this Material Specification and Material requisition supplementary design data, Standards, or Codes etc., shall be referred to Owner for clarification, before proceeding with the fabrication of the affected part.

Gasket Vendor shall be responsible to design fabricate and supply gaskets in accordance with requirements of applicable documents.

In no event, however, dimensions thicknesses etc., are to be less than those required by standards, unless specific written approval to the contrary is received from Owner.

2. GENERAL REQUIREMENTS

2.1 STANDARDS

ELOT EN 12560 (parts 1-4) and ELOT EN 1591-1

For Flanges **ELOT EN 1759-1** applies. For flanges with DN>600 not covered by this standard, dimensions given in ASME B16.5 apply.

2.2 TYPE AND MATERIAL

Spiral Wound, for raised face flange as per **ELOT EN 1759-1** table 3b, asbestos free, graphite, filled X5CrNiMo17-12-2 (stainless steel 1.4401, **ELOT EN 10088-3**) winding and inner ring. Carbon Steel solid ring type centering device.

2.3 MARKING

As a minimum the marking shall include:



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-PIP-035

Rev. 1

Page 6 of 7

- Vendor's mark.
- Type and Materials.
- **ELOT EN 12560 (parts 1-4)**

3. SUPPLEMENTARY REQUIREMENTS

Further requirements if specifically mentioned in the Material Requisition shall be valid. In case of conflict between such requirements and the requirements herein, the former shall prevail.

4. TECHNICAL DOCUMENTATION

4.1 QUANTITY

Four copies of each, inclusive of original for all documents and certificates. Also electronic files of all Documents, Drawings and Certificates must be submitted by Contractor to the Owner.

4.2 DOCUMENTS REQUIREMENTS

4.2.1 WITH TENDER

Catalogue/data sheet of product offered.

4.2.2 ON DELIVERY

Certificate as per **ELOT EN 10204**.

5. INSPECTION AND CERTIFICATION

Inspection requirements are defined in the following documents.

- a. Material requisition
- b. Job Specification DSF-SPC-QAC-005 "Shop inspection of equipment and material for NGT project"
- c. Relevant project specifications



Hellenic Gas Transmission System Operator S.A.
357-359 Messogion Av., GR 152 31 Halandri
Tel.: 213 088 4000
Fax: 210 674 9504
Email: desfa@desfa.gr

TECHNICAL SPECIFICATION

Doc No: DSF-SPC-PIP-035

Rev. 1

Page 7 of 7

d. Inspection clauses of applicable codes.